

BALES ENERGY ASSOCIATES

Date: April 21, 2014

DRAFT REVISIONS INCLUDING HEAT PUMP ANALYSIS

ENERGY STUDY FOR

Riverside/ Four Winds School
54 French King Highway
Gill, MA 01354



Completed By:

Bales Energy Associates

www.balesenergy.com

50 Miles Street

Greenfield, MA 01301

413-863-5020

Consulting Energy Engineer:

Bart Bales, PE, MSME

bart.bales@balesenergy.com

TABLE OF CONTENTS

Introduction.....	4
Executive Summary.....	4
Energy Conservation Opportunities Evaluated	4
Executive Summary Chart	5
Existing Conditions.....	6
Facility Description	6
Utility Energy Use	6
Billed Energy Use Chart of Electricity & Fuel.....	6
Heating Ventilating & Air Conditioning Systems.....	7
Boiler	7
HVAC Improvement Measure Options	8
Option 1: Convert Existing Steam System to Propane-Fired Condensing Boiler with Hydronic Distribution	
Option 2: Convert Existing Steam System to Water-to-Water Ground-Source Heat Pump System with New Fan Coils and Hydronic Distribution	
Option 3: Installation of Distributed Split System Air-to-Air Heat Pumps	
Heating Distribution Systems	8
Ventilation Considerations	9
Building Temperature & Scheduling Controls.....	10
Domestic Hot Water Heating Systems.....	10
Electrical Systems	11
Lighting Systems	11
Building Enclosure.....	11
Roof and Attic.....	11
Recommendation for Attic	12

Walls	12
Recommendation for Wall	12
APPENDICES.....	13
Calculations & Details:	
Heating System Improvement Measures	14
Option 1: Conversion to Hydronic Operation & Install Propane-Fired Condensing Boiler	15
Space Heating Savings Chart.....	15
Lochinvar Boilers	16
Option 2: Convert Existing Steam System to Water-to-Water Ground-Source Heat Pump System with New Fan Coils and Hydronic Distribution.....	24
Option 3: Installation of Distributed Split System Air-to-Air Heat Pumps	28
Wall & Attic Insulation & Air Sealing Measure Information	29
Summary of Energy Savings Due to Attic Insulation Chart	29
Summary of Energy Savings Due to Wall & Attic Insulation Chart	31
Annual Heat Balance - Existing Condition	31
Heat Balance Chart	32
Conduction Losses Chart	32
Infiltration Losses Chart	32
Heat Loss Coefficients Chart.....	34
Window Solar Heat Gain Chart.....	34
Temperature & Schedule Information Chart.....	34
Annual Building Heat Loads After Attic Insulation & Air Sealing	34
Heat Load After Attic Insulation Chart	34
Conduction Losses Chart	34
Infiltration Losses Chart	34
Heat Loss Coefficients Chart.....	35
Annual Building Heat Loads After Wall & Attic Insulation & Air Sealing	38
Heat Load.....	38
Conduction Losses Chart	38
Heat Loss Coefficients Chart.....	38

Introduction

Bales Energy Associates, an energy efficiency engineering firm, was contracted to provide an ASHRAE Level 2 energy audit for Riverside/Four Winds School located at 54 French King Highway in Gill, Massachusetts.

Bart Bales, PE, MSME, senior engineer at Bales Energy Associates, visited the site, reviewed energy usage & billing information, examined relevant equipment and systems, and developed energy analyses and recommendations with regard to building's energy related systems.

Executive Summary

Energy Conservation Opportunities Evaluated

Bales Energy Associates has approached the Riverside/Four Winds School in terms of the whole system. Improvements in various systems have interactive impacts with other systems. Key conclusions are the following:

1. HVAC Systems Recommendations

Option 1: Convert Existing Steam System to Propane-Fired Condensing Boiler with Hydronic Distribution

- **Convert the existing steam system to hydronic operation using existing piping where feasible**
- **Re-use existing radiators in the classrooms and historical room**
- **Replace radiators not compatible with hydronic operation (in the hallway and office) with radiative panel convectors**
- **Install a propane-fired, premium efficiency condensing hydronic boiler (with propane fuel storage tank capacity) to provide hot water to the building. Install necessary pump capacity to deliver heating water to the radiators and convectors serving building**
- **Boiler replacement includes installation of microprocessor-based scheduling time-clock capabilities** to provide scheduling of occupied and unoccupied periods. Install an outdoor air temperature sensor and a space temperature sensor. Use space temperature and outside air sensor inputs sensors to determine when boiler and circulator shall run for daytime temperature maintenance, and unoccupied temperature setback.

Option 2: Convert Existing Steam System to Water-to-Water Ground-Source Heat Pump System with New Fan Coils and Hydronic Distribution

Option 3: Installation of Distributed Split System Air-to-Air Heat Pumps

2. Enclosure Improvements can substantially reduce the building's heat loss characteristics.

Recommendations include:

- **Insulate the attic area of the building to achieve an R-value of R60.** Add sufficient cellulose insulation (15 inches of blown cellulose to add approximately R55 to the existing ceiling

assembly) to achieve the desired attic floor assembly R-value (R60). Air seal bypasses and penetrations in the attic. Seal off no longer used natural ventilation ductwork where it penetrates the ceiling.

- **Install dense pack cellulose in the building walls cellulose (4 inches, R14).**

The costs, savings, and economic payback for these energy conservation measures are presented in the following Executive Summary Chart. The values shown in the Executive Summary Chart represent the savings with measures taken in the order of economic feasibility shown. The calculations supporting each measure are included in the appendices.

																Executive Summary Chart		
																Oil	Propane	Electricity
																\$2.98	\$2.15	\$0.14
																\$/Gallon	\$/Gallon	\$/KWH
ECM #	Energy Conservation Measures	Cost	Incremental Cost (\$)	Available Incentives (\$)	Total Cost after Incentives (\$)	Incremental Cost after Incentives (\$)	Oil Savings (Gallons/yr)	Propane Savings (Gallons/yr)	Electricity Savings (KWH/yr)	Annual Savings (\$/yr)	Total Payback (yrs)	Incremental Payback (yrs)	Total Payback after Incentives (yrs)	Incremental Payback after Incentives (yrs)	Life Years			
ECM1	Option 1: Propane-Fired Condensing Boiler	\$52,030	\$17,138	0	\$52,030	\$17,138	1,777	-1,678	-	\$1,689	30.8	10.1	30.8	10.1	20+			
	Option 2: Ground Source Heat Pump	\$142,272	\$107,380	\$30,091	\$112,181	\$77,289	1,777		-12,790	\$3,454	41.2	31.1	32.5	22.4	30+			
	Option 3: Air Source Heat Pump	\$64,832	\$29,940	\$1,047	\$63,785	\$28,893	1,777		-16,764	\$2,881	22.5	10.4	22.1	10.0	30+			
ECM2	Insulate & Air-Seal the Attic	\$7,828	\$7,828	0	\$7,828	\$7,828		308		\$661	11.8	11.8	11.8	11.8	30+			
ECM3	Insulate the First Floor Walls	\$6,528	\$6,528	0	\$6,528	\$6,528		851		\$1,830	3.6	3.6	3.6	3.6	30+			
Totals		\$273,490	\$168,814	\$31,137	\$242,352	\$137,676	5,331	-519	-29,554	\$10,515	26.0	16.1	23.0	13.1				

Existing Conditions

Facility Description

The Riverside/Four Winds School is a moderate sized wood-framed, sloped-roofed building located at 54 French King Highway, in Gill, Massachusetts. The building comprises a basement (currently used only for storage) and a first floor with two large classrooms, a former classroom now used by the historical society and administrative offices.

The building is owned by the town and currently leased to the Four Winds School.

Utility Energy Use

Utility data was collected and is tabulated below. Western Massachusetts Electric Company provides electricity. For heating, the Riverside/Four Winds School uses #2 fuel oil. (Note: WMECO (and its parent company Northeast Utilities), recently merged with NSTAR. As a result, changes in procedures and personnel in charge of related utility programs are in transition.)

Jul 2012-June 2013 Energy Use Table for Electricity & Fuel					
Building Name	Riverside Building				
Owner	Town Of Gill, MA				
Account #					
Month	Electricity KWH	Electricity Total \$	Oil Gallons	Gas \$	Energy \$ Totals
Jul	109	\$24			\$24
Aug	122	\$27			\$27
Sept	212	\$47	64.0	\$191	\$237
Oct	442	\$97		\$0	\$97
Nov	422	\$93	205.0	\$611	\$703
Dec	411	\$90		\$0	\$90
Jan	544	\$120	320.0	\$953	\$1,073
Feb	412	\$91	695.0	\$2,070	\$2,161
Mar	375	\$83	197.0	\$587	\$669
Apr	426	\$94	296.0	\$882	\$975
May	325	\$72			\$72
Jun	237	\$52			\$52
Annual (Units)	4,037	\$888	1,777.0	\$5,292	\$6,181
Heating Season (Units)	3,032	\$667	1,777.0	\$5,102	\$5,769
				Energy Use Totals (Mbtu)	
Annual (Mbtu)	13,774		246,469.9	260,244	Energy \$ Totals
Heating Season (Mbtu)	10,345		246,469.9	256,815	
\$/Energy Unit				Totals (Mbtu/sf)	(\$/sf)
Annual (Mbtu/sf)	2.3		40.3	42.6	\$0.87
Heating Season (Mbtu/sf)	1.7		40.3	42.0	\$0.83
Heating Season \$/Energy Unit					
Building Name	Riverside Building		Heated Square Footage	6,114	

Prescriptive and custom utility incentives are available for some of the measures described. When the report's contents are accepted by the client, the report may be presented to the utilities for review and determination of levels of custom incentives the utilities will offer, if any.

Western Massachusetts Electric Company contacts are: Lynn Ditullio (ditullb@nu.com) and Robert Dvorchik (dvorcrs@nu.com).

Heating, Ventilating & Air Conditioning Systems

Boiler

The building is served by a very old five-section, oil-fired, atmospheric steam boiler (HB Smith, 2000A/2000L/200L Mills) with a rated steam output capacity of 255,100 Btu/hour. The boiler has an estimated combustion efficiency of approximately 80%. (The most recent combustion test tag indicated performance at 65%, but the boiler appears to have been equipped more recently with a new Carlin burner.) There is no outside air intake through the boiler wall to provide combustion air.



THE H. B. SMITH CO., INC. WESTFIELD, MASS.							
2000A/2000L/200L SMITH MILLS BOILER BURNER UNIT							
REG. U.S. PAT. OFF.							
NO. SECTS.	SQ. FT. STEAM	I=B=R NET RATINGS BTU/HR.		I=B=R BURNER CAPACITY LIGHT OIL GAL./HR.		VALVE CAPACITY *LBS./HR.	
		STEAM	WATER	2000A&L	200L	MBH	
4	840	201,000	233,000	2.50	2.55	357	268
5	1065	255,100	295,700	3.15	3.20	448	340
6	1290	309,100	358,300	3.80	3.85	539	412
7	1515	363,100	420,900	4.45	4.50	630	484
MAX. W.P. STEAM		15 P.S.I.		* A.S.M.E. VALVE CAPACITY			
		WATER 40 P.S.I.		1000 BTU = 1 LB. STEAM			
MEMBER THE HYDRONICS INSTITUTE							

Recommended Boiler Improvement Measure Options

Option 1: Convert Existing Steam System to Propane-Fired Condensing Boiler with Hydronic Distribution

- Convert the existing steam system to hydronic operation using existing piping where feasible
- Re-use existing radiators in the classrooms and historical room
- Replace the four radiators not compatible with hydronic operation (in the hallway and office) with radiative panel convectors
- Install a propane-fired, premium efficiency condensing hydronic boiler (with propane fuel storage tank capacity) to provide hot water to the building. Install necessary pump capacity to deliver heating water to the radiators and convectors serving building
- Boiler replacement includes installation of microprocessor-based scheduling time-clock capabilities to provide scheduling of occupied and unoccupied periods. Install an outdoor air temperature sensor and a space temperature sensor. Use space temperature and outside air sensor inputs to determine when boiler and circulator shall run for daytime temperature maintenance, and for unoccupied temperature setback.

Option 2: Replace Existing Steam System to Water-to-Water Ground-Source Heat Pump System with New Fan Coils and Hydronic Distribution

This approach utilizes a water-to-water ground source heat pump system to provide conditioned water to ten new hydronic fan-coil units. Fan coil units will be installed to temper the various spaces. A new hydronic distribution loop will deliver water to each fancoil. Re-use of the existing radiators is not appropriate due to the lower water temperatures provided by the heat pump system.

Note that an added advantage of the heat pump system is that air conditioning capability is added for the building.

The ground-source borehole system comprises 6 boreholes of 330 foot depth

Option 3: Replace Existing Steam Heating System with Distributed Air-to-Air Split System Heat Pumps

This approach utilizes nine (9) new air-to-air source heat pumps to provide conditioned air to directly condition the various spaces.

Note that an added advantage of the heat pump system is that air conditioning capability is added for the building.

Heating Distribution Systems

The building is a one-pipe steam heating system (with a “drip leg” at the end of the supply line to allow condensate to return to the boiler (below the boiler’s “water-line”). Given the convenient location of the steam piping running all the way around the perimeter of the building and the central location of the boiler, it is possible for the existing steam piping to be considered for re-use to deliver water as a heating medium with a limited amount of added piping required.

Prior to implementation of re-use of the steam pipe for water distribution pipe, it is recommended that the pipe be air-tested at elevated pressures to assess the potential presence of any leaks. (A hydronic system works at higher pressures than a steam system; a hydronic system might be expected to operate at approximately 60 psig, while a low-pressure steam system such as the one at the Riverside School would be expected to typically operate at pressures of 5 to 10 psig.)

Terminal heating is provided by radiators in all areas except one. The type of radiator found in the classrooms is shown below. It may be seen to be a one-pipe radiator with a steam valve on one end and an air relief valve on the other. The presence of screw fitting on the top and bottom manifolds of each end of the radiator indicate that these radiators were designed for use with either steam or hot water and that they are potentially able to be converted to hydronic operation.



Ceiling mounted radiators of similar function and slightly different configuration serve the seldom-used basement lavatories.

The four radiators in the office and the front hallways do not have top manifolds that connect the sections and are not equipped with screw fittings. These radiators are not as readily converted for use in a hydronic system. Thus, in converting the building to hydronic operation, these radiators would be recommended for replacement with convective radiator panels.

In one basement storage area (former cafeteria of many years ago) there is a length of ceiling mounted fin-tube radiation. This radiation may be potentially re-used for hydronic operation to provide heat to the storage area.

In the other large storage area in the basement (at one time used by the police department), it appears that a section of radiation has been removed. In the final conversion of this building, an assessment of whether to add radiation to this area or not should be made.

Ventilation Considerations

The building was designed for thermally driven “natural” ventilation. Radiators located in ducts would provide sufficient heating of air in the ducts that it would rise to leave the building via large ducts leading to the large cupola on the top of the building. The air leaving the building would be replaced by un-tempered outside air leaking into the building through various elements of the building construction.

This system stopped being used when energy prices increased. One of the radiators in the ducts was noted to have been removed. Another duct radiator remained in place but the valve which served it was

locked closed. With no thermal energy to drive the process, cool air would sometimes “drop” down the ducts and bring cool air into the space to which it was attached.

In the picture below, it may be seen that the exhaust grill has been blocked with a rectangle of foam board to block the air flow.



Note that the metal ducts attached to this ventilation system are large and that they penetrate the ceiling and continue on into the unheated attic and then connect to the large metal cupola at the peak of the attic. In effect, these ducts, located inside the building's thermal envelope, serve as fins to conduct thermal energy from the heated space to the unheated attic and also to the outdoors.



Since these ducts are no longer being used for ventilation, it may be useful to consider sealing the locations where they pass through the ceiling. Though not an energy-savings measure in this particular case, the Town may wish to consider installing an energy-recovery ventilator to provide a more assured supply of outside air to the two classrooms when the air sealing and insulation measures are being completed. (Alternately, the spaces can continue to use the operable windows if added ventilation air is felt to be required.)

Building Temperature & Scheduling Controls

Operation of the boiler is controlled by a single manual thermostat serving the building.

As part of the boiler conversion replacement measure, Bales Energy Associates **recommends installation of an electronic programmable timeclock capacity and an outdoor air sensor and an indoor space sensor.** Hydronic supply water temperatures would be reset to different levels depending on the outside air temperature. Outdoor temperature reset capability is critical to allow a boiler designed for condensing operation to actually condense the water vapor out of its exhaust to capture a greater percentage of the total energy available from the fuel being burned.

Domestic Hot Water Heating Systems

Hot water is provided by a 2.5 gallon mini-tank tank electric water heater (Ariston Model 2.5 Ti). Given the very low water use in the building, this is an efficient way to provide the limited quantities of warm water that are required. Water usage is low in the building; water uses are limited to a lavatory sink on the first floor. Other than encouraging the town to insulate the three feet of un-insulated ½ inch domestic hot water pipe leading from the mini-tank in the basement to the lavatory on the floor above, Bales Energy Associates makes no recommendations with regard to domestic hot water system improvements.



Electrical Systems

Lighting Systems

Classrooms and offices in the building are lighted with four foot fluorescent fixtures equipped with T-8 lamps and compatible electronic ballasts.

Building Enclosure

The partially finished basement and first floor of the Riverside/Four Winds School comprise approximately 6,114 square feet of heated floor area. All school activities take place on the first floor which comprises two classrooms and administrative offices, plus one classroom which is used by the historical society.



The basement is currently only used for storage.

Roof and Attic

The Riverside/Four Winds School has a sloped-roof with a metal ventilation cupola on top.

The attic is unfloored and has 2 to 3 inches of rock wool insulation in place. Large metal ductwork designed for use by the heat-driven natural ventilation system penetrates the first floor ceiling and continues on through the attic to the metal exhaust cupola on the roof. The ducts represent a large air bypasses. There are also bypasses from the first floor to the attic through the spaces around the duct work.

Recommendation for the Attic

Bales Energy Associates recommends that the attic floor joists be treated as the location of a thermal and air boundary layer. This involves the following steps:

1. Retain the cupola for ventilation out of the attic.
2. Insulate the attic floor assembly to add approximately 15 inches of loose-fill cellulose insulation (R55) to the attic to achieve a roof assembly value of R-60.
3. Air-seal the attic area to reduce infiltration.

Costs and savings for this measure are included in the Appendices.

Walls

The walls of the Riverside/Four Winds School are poorly insulated.

Recommendation for the Wall

Bales Energy Associates recommends that insulating the four inch wall assembly with approximately four inches of high-density cellulose (R14) insulation.

Costs and savings for this measure are included in the Appendices.

APPENDICES

HEATING SYSTEM IMPROVEMENT MEASURES

Conversion of System to Hydronic (Hot Water) Operation & Installation of Propane-Fired Condensing Hydronic Boiler

Space Heating Savings with Propane-Fired Condensing Hydronic Boiler						
Gill Riverside/Four Winds School						
Gill, MA						
Oil Rate (\$/gallon)	Existing Condition:				New Condition:	
\$2.98					\$2.15	
Equipment Type	Space Heating Boiler			Space Heating Boiler		
Boiler #	1			1		
Make	H B Smith			Lochinvar		
Model	2000A/2000L/200L Mills			Knight		
Type	Atmospheric			Condensing		
Heating Medium	Steam			Hydronic		
Control Mode				Modulating 5:1		
Maximum Output Mbtu/hr	255			150		
Steady State Eff	80%			92%		
Input Mbtu/Hr	319			163		
Seasonal Eff	65%			92%		
Percentage of Load	100%			100%		
Installed System Costs		High-Performance Heating System				
Boiler	\$34,892	Propane-Fired Condensing Boiler with 4 new radiators, conversion of other existing radiators, circulator, controls and required piping changes			\$40,030	
		Propane tank			\$7,000	
		System Configuration Contractor Oversight			\$5,000	
Totals	\$34,892				\$52,030	
Annual Building Operating Load (MMbtu/year)	Summary of Existing Building-Related Heat Loads	Existing Oil Heating Usage Gallons	New Propane Heating Usage Gallons	Fuel Cost \$	Peak Space Heating Load (Mbtu/hr)	Provide (#) Boilers @ 100% of design Load
160,205	Existing Oil Use	1,777		\$5,295	150	150
160,205	New Propane Use		1,678	\$3,607		
KWH						
Fuel Energy Before	246,470					
Fuel Energy After	174,136					
Fuel Energy saved	72,334			Savings \$	\$1,689	
Payback Calculation:						
		Cost	Savings	Payback		
Full Equipment Cost Basis:		\$52,030	\$1,689	30.8		
Incremental Equipment Cost Basis:		\$17,138	\$1,689	10.1		

LOCHINVAR BOILERS

For more than 80 years, Lochinvar has played a legendary role in commercial water heating. Now we're bringing that proven performance to the condensing market with the KNIGHT—today's most advanced fully modulating high-efficiency condensing boiler.

The KNIGHT is an installer's dream: lightweight and compact, with key components that are easy to access. The Lochinvar KNIGHT offers PVC venting versatility, rugged reliability, seven models with inputs ranging from 80,000 to 500,000 Btu/hr, and 93% DOE AFUE. And you'll love the SMART SYSTEM^a control, which includes a service indicator, contractor accessible password protection, and a 2-line display with simple fault descriptions, not codes. Best of all, the KNIGHT offers more standard features than any other heating boiler available today—including outdoor reset and a boiler circulating pump supplied with every KB 080-285 unit. Plus every KNIGHT is backed by an outstanding 12-year warranty.

1.1 FEATURES

- Stainless steel heat exchanger
- Fully modulating burner w/5:1 turndown
- PVC venting - up to 100 ft.
- Boiler circulating pump included
- Direct vent, sealed combustion



the best
mod/con Performance
and Versatility

UP TO
96%
DOE AFUE
Efficiency



Now with Floor and
Wall Mount Models



Lochinvar[®]
High Efficiency Water Heaters, Boilers and Pool Heaters

www.knightheatingboiler.com

a

Legendary Performer...



Since its introduction in 2005, the KNIGHT modulating-condensing heating boiler has consistently delivered everything the professional needs for ease of installation and maintenance, and everything homeowners need for total comfort and long-term savings on energy costs.

Now, with 5 floor-standing models and 5 compact Wall Mount units, Lochinvar offers the industry's broadest selection of modulating-condensing heating boilers. And KNIGHT is the industry's most advanced boiler design, including the SMARTSYSTEM™

operating control that has quickly become a legendary benchmark among the trade!

For traditional space heating or radiant floor heating applications, KNIGHT offers your customers tremendous savings on energy costs compared to less efficient boilers. KNIGHT has earned the ENERGY STAR,



signifying that it has met strict energy-efficiency guidelines set by the EPA and U.S. Department of Energy.

10 Models – The Right Choice, for Every Application



"After my first KNIGHT installation, I loved it so much I installed it in my own home, and now my heating bill is half what it used to be."

– Rick Brunner, Hydronic Solutions, Nassau County, NY

KNIGHT is a great choice for radiant floor heating, baseboard and panel heater applications.

is joined at the Round Table



"Why do I like the KNIGHT? I don't know where to begin. The direct venting with 100 feet of intake and exhaust eliminates a lot of problems. I also like the low voltage features, and the SMART SYSTEM's outdoor reset capability. The internal sequencer is tremendously powerful and ideal for multiple boiler installations. It's also great-looking, and aesthetics are important to my customers. When I install KNIGHT, my customers know they are getting a highly efficient state-of-the-art system, and they've all been completely satisfied."

– Paul Rohrs, Biggerstaff Radiant Solutions, Lincoln, NE



**KNIGHT lineup now includes 5 space-saving
Wall Mount models from 50,000 to 210,000 Btu/hr**



**The KNIGHT floor-standing
lineup features 5 small
footprint designs from
80,000 to 285,000 Btu/hr**



All KNIGHT Boilers
meet or exceed
the highest federal
emissions
requirements.

KNIGHT plus SQUIRE delivers domestic hot water for less!

The KNIGHT boiler's DHWP feature means you can easily install it with Lochinvar's new SQUIRE indirect water heater. With this winning combination, homeowners will get high-efficiency space heating from KNIGHT, plus all the domestic hot water they need from SQUIRE. Equipped with a stainless steel tank and heat exchanger, SQUIRE will provide more hot water with lower water heating costs compared to a standard gas or electric water heater.



**SMART
SYSTEM**

& the Industry's Smartest Design

SMART SYSTEM is the industry's most advanced operating control. Right out of the box, it gives you unequaled control and monitoring functions that are easy to understand and use.



"I really like the KNIGHT Boiler because it's very simple to install and program. The SMART SYSTEM control is great and I really like being able to troubleshoot with the pocket PC. My customers choose KNIGHT for its high efficiency and state-of-the-art design, and they're all thrilled that KNIGHT operates so quietly and makes their home much more comfortable."

— Chad Padilla, TLC Plumbing, Albuquerque, NM

2-Line, 16-Character LCD Display

Displays setup and diagnostic information in words, not codes

Password Security

Dual passwords for installer and user

Product Service Indicator

Program reminders for cycle count, operation hours or last service

Pump Relay w/Freeze Protection

Ensures water temperature does not fall below 40°F

Low-Water Flow Indicator

Protects against high temperature differential in the heat exchanger with reduced modulation or shutdown

Outdoor Reset

Outdoor temperature monitor guides the reset schedule to meet load

Night Setback

Program a heating loop water temperature setback for any time of the day, each day of the week

Building Management System (BMS) Control

0-10 VDC, BMS-driven input for modulation rate or temperature control

DHWP with Pump Control

On call for hot water, SMART SYSTEM overrides outdoor reset and starts DHWP pump to the indirect. Runtime can alternate between heating and domestic hot water to meet demand simultaneously

System & Boiler Pump Controls

Provides power to both system and boiler pumps based on a call for heat. Programmable delay allows pumps to operate after a call has been satisfied

In/Out Temp. Sensors and Display

Allows installer to select which sensor controls the boiler setpoint



PC Connection –

Can be used with KNIGHT PC or Pocket PC software to troubleshoot and program SMART SYSTEM functions and to track historical data, including faults, trends and energy consumption.

Field Connection Versatility

User-friendly terminal strip allows for 28 low-voltage field connections. Plus, 4 line voltage connections supply power to the unit, and up to three pumps operated by the SMART SYSTEM.

Built-in Cascading Sequencer

SMART SYSTEM includes a built-in sequencer for 2–8 units, eliminating the cost and labor of a third-party sequencer. On demand, one boiler acts as lead unit and modulates with demand to meet capacity. The additional load then "cascades" to the next boiler in line and continues all are operating or demand is satisfied. When demand drops, the process reverses.




"The control system on the KNIGHT is head and shoulders above anything else available. Straight out of the box, the KNIGHT can do anything I need without third-party controls. Hands-down, it's the best boiler on the market."


— Don Smet, Standard Plumbing Heating Controls Corp., Spokane, WA



Knights Heating Boiler Dimensions & Specifications– Floor Standing Models



Wall Mount Models



Model		Input				Heating Capacity		NET I=B=R		Dimensions and Specifications													Gas				Water		Air		Vent		Shipping
Number	MBH	Min MBH	Max MBH	AFUE %	Capacity MBH	Capacity MBH	Capacity MBH	I=B=R	A	C	D	E	F	G	H	I	J	K	M	Conn.	Conn.	Inlet	Size	Weight	Conn.	Conn.	Inlet	Size	Weight				
WBN050	10	50	95.3	45	39	29-1/4"	15-3/4"	NA	10-3/4"	10-3/4"	2"	6-3/4"	NA	3-1/4"	4-1/4"	2-3/4"	1/2"	1"	2"	2"	130	1/2"	1"	2"	2"	130							
WBN080	16	80	95.3	72	63	29-1/4"	15-3/4"	NA	10-3/4"	10-3/4"	2"	6-3/4"	NA	3-1/4"	4-1/4"	2-3/4"	1/2"	1"	2"	2"	130	1/2"	1"	2"	2"	134							
WBN105	21	105	95.4	97	82	29-1/4"	15-3/4"	NA	10-3/4"	10-3/4"	3-1/2"	5-1/2"	NA	3-1/4"	4-1/4"	2-3/4"	1/2"	1"	2"	2"	134	1/2"	1"	2"	2"	162							
WBN150	30	150	95.5	135	119	29-1/4"	20-3/4"	NA	15-3/4"	8-1/2"	3-1/2"	5-1/2"	NA	8-3/4"	9-3/4"	1-1/2"	1/2"	1"	3"	3"	162	1/2"	1"	3"	3"	177							
WBN210	42	210	95.7	190	165	29-1/4"	25"	NA	20"	12"	3-1/2"	5-1/2"	NA	13"	14"	1-1/2"	1/2"	1"	3"	3"	177	1/2"	1"	3"	3"	125							
KBN080	16	80	95.3	72	63	33-1/4"	14"	7"	5-3/4"	5"	3"	20-1/2"	22"	1-3/4"	6-1/2"	NA	1/2"	1"	3"	3"	125	1/2"	1"	3"	3"	129							
KBN105	21	105	95.4	97	82	33-1/4"	14"	6-1/2"	5-3/4"	4-1/2"	1-1/2"	20-1/2"	22"	1-3/4"	6-1/2"	NA	1/2"	1"	3"	3"	129	1/2"	1"	3"	3"	157							
KBN150	30	150	95.5	135	119	33-1/4"	18"	12-1/4"	11-1/2"	10"	1-1/2"	21-1/4"	23"	1-3/4"	12"	NA	1/2"	1"	3"	3"	157	1/2"	1"	3"	3"	172							
KBN210	42	210	95.7	190	165	33-1/4"	22-1/4"	16-1/2"	15-3/4"	14-1/4"	5-1/4"	21-1/4"	23"	1-3/4"	16-1/4"	NA	1/2"	1"	3"	3"	172	1/2"	1"	3"	3"	224							
KBN285	57	285	96.0	260	226	42-1/2"	19-3/4"	12-3/4"	13-1/2"	6"	2"	34"	31"	11-3/4"	4-1/4"	NA	3/4"	1-1/4"	4"	4"	224	3/4"	1-1/4"	4"	4"								

Notes: Performance data based on manufacturer's test results. Indoor installation only. All information subject to change. Change "N" to "L" for LP gas models.

Standard features in **BOLD** text indicate equipment you would pay extra for on competing models.

Standard Features

- › ENERGY STAR® Qualified
- › Modulating Burner with 5:1 Turndown
- › ASME Stainless Steel Heat Exchanger
- › Gasketless Heat Exchanger Design
- › 30 psi Relief Valve
- › **SMART SYSTEM™ Operating Control, with:**
 - Digital Operating Control
 - 2-Line, 16-Character LCD Display
 - Password Security
 - Outdoor Reset
 - Built-in Sequencing for 2-8 Boilers
 - 0 – 10 Vdc Input Control
 - Product Service Indicator
 - Time Clock
 - PC Connection Port
- › Inlet & Outlet Temperature Sensors
- › Easy-Access Terminal Strip

- › Low-Water Flow Indication
- › Automatic Reset High Limit
- › **Contacts on Any Failure**
- › **3-Pump Control (Boiler, System and DHWP)**
- › Pump Relay with Freeze Protection
- › **Boiler Circulating Pump (KBN080-285) (WBN050-210)**
- › Direct-Spark Ignition
- › Low-NOx Operation
- › Natural to LP Gas Conversion Kit
- › Direct-Vent Sealed Combustion
- › PVC Venting up to 100 Feet
- › Sidewall Vent Terminals
- › Zero Clearance to Combustibles
- › Adjustable Leveling Legs (KBN Models only)
- › Wall Mount Bracket (WBN Models only)
- › 12-Year Limited Warranty (See Warranty for Details)

Optional Equipment

- › Adjustable High Limit with Manual Reset
- › Flow Switch
- › Low-Water Cutoff with Manual Reset and Test
- › Alarm Bell on Any Failure
- › SMART SYSTEM™ PC Software
- › Concentric Vent Kit
- › Condensate Neutralization Kit
- › Multi-Stack Frame (KBN Models only)



300 Maddox Simpson Parkway, Lebanon, TN 37090 | 615-889-8900 | fax: 615-547-1000 | www.lochinvar.com

KBN-04 (Replaces KBN-03 8/07)

MK-20M-2/08-Printed in U.S.A.

Conversion of System to Hydronic (Hot Water) Operation & Installation of Fan-Coil Units Served by Water-to-Water Ground-Source Heat Pumps

Space Heating Savings with Water-to-Water Ground-Source Heat Pump System							
Gill Riverside/Four Winds School Gill, MA						Electricity \$/KWH	
Oil Rate (\$/gallon)	Existing Condition:			New Condition:		\$0.144	
\$2.98							
Equipment Type	Space Heating Boiler			Ground-Source Heat Pump			
Boiler #	1			2			
Make	H B Smith			Hydron			
Model	2000A/2000L/200L Mills			Heat Pumps (2)	HWT092 (ELT-110/50)		
Type	Atmospheric			Fan Coil Units (10)	MHWW-18-H-3		
Heating Medium	Steam			Water-to-Water			
Control Mode				Rating (tons)	14.5		
Maximum Output Mbtu/Hr	255					174	
Steady State Eff	80%					294%	
Input Mbtu/Hr	319					59	
Seasonal Eff	65%					367%	
Percentage of Load	100%					100%	
Installed System Costs		High-Performance Heating System					
Boiler	\$34,892	Two (2) Water-to-Water Heat Pumps Serving Ten (10) Fan-Coil Units Ground-Coupling: Borefield with Six (6) 330 Foot Boreholes					
					\$114,000	Cost information provided by Richard Baker contractor quotes not yet requested	
		Four Networkable Programmable "Smart" Thermostats			\$3,580		
					Subtotal		\$117,580
					Contingency		\$11,758
					Subtotal		\$129,338
		System Configuration Contractor Oversight			\$12,934		
Totals	\$34,892	Total			\$142,272		
Annual Building Operating Load (MMbtu/year)	Summary of Existing Building-Related Heat Loads	Existing Oil Heating Usage Gallons	New Electricity Heating Usage KWH	Fuel Cost \$	Peak Space Heating Load (Mbtu/hr)	Provide (#) Boilers @ 100% of design Load	
160,205	Existing Oil Use	1,777		\$5,295	174	174	
160,205	New Electricity Use		12,790	\$1,842			
KWH							
Fuel Energy Before	246,470						
Fuel Energy After	43,653						
Fuel Energy saved	202,817		Savings \$	\$3,454			
Payback Calculation:							
		Cost	Savings	Payback	Incentive per Ton		
Full Equipment Cost Basis:		\$142,272	\$3,454	41.2			
Renewable Thermal Incentive (CEC/DOER)		-\$28,933			\$2,000		
Utility Incentive (Mass-Save)		-\$1,157			\$80		
Full Equipment Cost Basis after Incentive:		\$112,181	\$3,454	32.5			
Incremental Equipment Cost Basis:		\$107,380	\$3,454	31.1			
Renewable Thermal Incentive (CEC/DOER)		-\$28,933					
Utility Incentive (Mass-Save)		-\$1,157					
Incremental Equipment Cost Basis:		\$77,289	\$3,454	22.4			

Ground-Source Heat Pump Data for Riverside-4 Winds School

From Baker GSHP Preliminary Report

Project: Gill Riverside Building HVAC upgrades

Prepared: March 13, 2014

Prepared By: Richard Baker, IGSHPA 24526-0209

RE: GSHP Preliminary Report Gill Riverside Building

System Loads

System loads or peak loads are calculated based on a variety of details for an individual facility, assumed occupancy levels, the number of appliances operating, the number of doors & windows, and the tightness of the construction all contribute to the amount of energy required to maintain the thermostat set points given the historical extreme weather conditions in your area.

1 kBtu/hr = 1,000 Btu/hr

Zone	Total Heating Load	Total Cooling Load	SHF
Zone 1	150.0 kBtu/hr		0.900
Total	150.0 kBtu/hr		

1. Peak Loads used here as provided by: Bart Bales, PE
2. This report is primarily concerned with heating load and associated operational costs therefore cooling load is not being considered at this point.

Equipment Schedule

Based on the provided loads and space configuration considerations, the preliminary GSHP equipment schedule for this system is as follows:

Zone	Equipment	QTY	Heat Capacity KBtu/hr (Low Stage)	Heat Capacity kBtu/hr (High Stage)	Water Flow (GPM)	Air Flow (CFM)
Central Source	Hydron Module – HWT092 (ELT-110/50)	2	136.00	173.60	52.0	
Distributed	MHWW-18-H-3	10		185.22	52.0	480

1. All capacities shown are total
2. For water to water equipment, source and load water flows are assumed equal.
3. Capacities are adjusted for 32F EWT and Glycol protection to 15F with EAT 70F and ELT 110F
4. When equipment allows continuous fan operation is recommended
5. Avoid using dramatic night time set back
6. Air Flow rates are reported on a per unit basis. For total air flow in a zone, multiply the reported air flow by quantity.
7. Installed GSHP COP 2.94 High Capacity and 4.17 Low Capacity

GSHP SelectionManufacturer: **Hydron Module**Model: **HWT092**Heat Pump Type: **Water to Water** Capacity: **Dual**

		GSHP
--	--	------

Installation Cost		\$114,000.
----------------------	--	------------

Ground Heat Exchange Summary

Grout is used inside of all bores in order to protect the deep earth environment from surface contaminants and to provide a more effective contact surface with GHEX piping that optimizes heat transfer between the fluid pumped through your GSHP and the earth. Deep Earth (below 20ft) temperature is a function of the average annual air temperature in your region and remains relatively constant regardless of season.

Deep Earth Temp (T_g) 52.0 F

Formation T.C.	1.30 Btu/hr ft F
Grout T.C.	1.00 Btu/hr ft F
EWT _{min}	30.0F
EWT _{max}	90.0F
Bore Diameter	6.00 in
Pipe Diameter	1.25 in
Bores in Series	1
Layout Rows	1
Bores per Row	6
Number of Bores	6
Bore Spacing	25.0 ft on center
Bore Depth	296 ft
Adj. Bore Depth*	330 ft
System Run Fraction	0.507

Adj. Bore Depth is the adjusted bore depth. This is the depth of bore that should be used to accommodate unbalanced ground loads over time. A pre-construction test bore is recommended.

Grouting the bore annulus: Each vertical bore is to be grouted from the bottom to the top. Grout field mix T.C. testing is recommended. Grout Recommendation: TGLite by GeoPro Inc.

GHEX Piping:

Vertical Bore: 1.25" HDPE SDR-11 with factory u-bend

Horizontal Piping:

From Bore to Building all pipe should be a minimum of 4' below grade.

Supply lines should be below Return lines.

2" foam board insulation should separate supply and return lines when feasible.

2" foam board insulation should be above return lines when feasible.

Horizontal piping should be in backfill free from material that may be a hazard to the pipe.

GHEX Manifold:

Vertical bore loopfield will be (3) individual closed loop circuits bringing in a total of (6) 1.25" supply and (6) 1.25" return lines. Interior piping: install full port valves on each supply and each return to a common supply and common return header. Install fill and drain ports followed by full port valves on header. Connect supply and return to pumping station.

Note: Mechanical or 'Stub' fittings are not recommended for any portion of exterior below grade piping. All exterior below grade pipe connections are to be by fusion of HDPE pipe and HDPE fittings.

Wall penetrations to be sealed with 'link seal' style fittings inside pvc sleeve. Sleeve sealed with either silicone, hydrolic cement or similar.

Recommended freeze protection – 22% to 15 F with Propylene Glycol

System Sequencing

1. Individual Fan Coil thermostat calls for conditioning
2. Hydronic circulation begins to and from conditioned Water Storage Tank
3. Water Storage Tank aqua-stat calls for conditioning
4. GHEX circulator pump responds causing flow in GHEX
5. GSHP provides desired conditioning to Water Storage Tank

It is recommended that where GSHP equipment allows that the fan be set to on at all times. This maintains desired air circulation blending conditioned air more evenly throughout the conditioned space. Doing this will reduce the circumstance of hot spot/cold spot improving occupant comfort and reducing overall energy consumption.

Equipment Efficiencies

Note: GSHP efficiencies shown below are system wide averages which include pumping and applicable resistance energy. ASHP efficiencies have been adjusted from manufacturer's stated HSPF to more closely reflect installed operation in your region.

GSHP (COP avg) 3.67 (for this application)

Installation of Split-System Air-Source Heat Pumps

Space Heating Savings with Split Air-Source Heat Pump System							
Gill Riverside/Four Winds School						Electricity	
Gill, MA						\$/KWH	
Oil Rate (\$/gallon)	Existing Condition:				New Condition:	\$0.144	
Oil Rate (\$/gallon)	Existing Condition:				New Condition:	\$0.144	
\$2.98							
Equipment Type	Space Heating Boiler			Air-Source Heat Pump			
Boiler #	1			2			
Make	H B Smith			Mitsubishi			
Model	2000A/2000L/200L Mills	MUZFE9NA (2)	MUZFE12NA (2)	MUZFE18NA (5)			
Type	Atmospheric	SEER: 26; HSPF:10	SEER: 23; HSPF:10	SEER: 20.2; HSPF:10.3			
Heating Medium	Steam			Air-to Air			
Control Mode			Rating (tons)	13.1			
Maximum Output Kbtu/Hr	255			157			
Steady State Eff	80%	Mean			280%		
Input Mbtu/Hr	319			56			
Seasonal Eff	65%			280%			
Percentage of Load	100%			100%			
Installed System Costs		High-Performance Heating System					
Boiler	\$34,892	Nine (9) Split-System Air-Source VRF Heat Pumps		\$50,000	<i>Cost information provided by Richard Baker contractor quotes not yet requested</i>		
		Four Networkable Programmable "Smart" Thermostats		\$3,580			
				Subtotal			\$53,580
				Contingency			\$5,358
				Subtotal			\$58,938
				System Configuration Contractor Oversight	\$5,894		
Totals	\$34,892			Total	\$64,832		
Annual Building Operating Load (MMbtu/year)	Summary of Existing Building-Related Heat Loads	Existing Oil Heating Usage Gallons	New Electricity Heating Usage KWH	Fuel Cost \$	Peak Space Heating Load (Mbtu/hr)	Provide (#) Boilers @ 100% of design Load	
160,205	Existing Oil Use	1,777		\$5,295	157	157	
160,205	New Electricity Use		16,764	\$2,414			
KWH							
Fuel Energy Before	246,470						
Fuel Energy After	57,216						
Fuel Energy saved	189,254			Savings \$	\$2,881		
Payback Calculation:							
		Cost	Savings	Payback	Incentive per Ton		
Full Equipment Cost Basis:		\$64,832	\$2,881	22.5			
Renewable Thermal Incentive (CEC/DOER)							
Utility Incentive (Mass-Save)		-\$1,047			\$80		
Full Equipment Cost Basis after Incentive:		\$63,785	\$2,881	22.1			
Incremental Equipment Cost Basis:		\$29,940	\$2,881	10.4			
Renewable Thermal Incentive (CEC/DOER)		\$0					
Utility Incentive (Mass-Save)		-\$1,047					
Incremental Equipment Cost Basis:		\$28,893	\$2,881	10.0			

Air Source Heat Pump Data for Riverside-4 Winds School

From Rich Baker ASHP Preliminary Report

Project: Gill Riverside Building HVAC upgrades
 Prepared: April 14, 2014
 Prepared By: Richard Baker, IGSHPA 24526-0209

RE: ASHP Preliminary Report Gill Riverside Building

System Loads

System loads or peak loads are calculated based on a variety of details for an individual facility, assumed occupancy levels, the number of appliances operating, the number of doors & windows, and the tightness of the construction all contribute to the amount of energy required to maintain the thermostat set points given the historical extreme weather conditions in your area.

1 kBtu/hr = 1,000 Btu/hr

Zone	Total Heating Load	Total Cooling Load	SHF
Zone 1	150.0 kBtu/hr		0.900
Total	150.0 kBtu/hr		

- Peak Loads used here as provided by: Bart Bales, PE
- This report is primarily concerned with heating load and associated operational costs therefore cooling load is not being considered at this point.

Equipment Schedule

Based on the provided loads and space configuration considerations, the preliminary GSHP equipment schedule for this system is as follows:

Zone	Equipment	QTY	Heat Capacity kBtu/hr (Low Stage)	Heat Capacity kBtu/hr (High Stage)	Water Flow (GPM)	Air Flow (CFM)
	MUZFE09NA	2		21,800		
	MUZFE12NA	2		27,200		
	MUZFE18NA	5		108,000		

- Equipment is Mitsubishi
- Heat Capacity is based on manufacturer data at 5F
- Heat Capacities shown are total
- AHRI#: FE09 – 4908219 : FE12- 4934170 : FE18- 4217888

Anticipated cost to install: \$ 50,000.

WALL & ATTIC INSULATION MEASURE INFORMATION

School

	Location	Measure	Depth	R-Value	# / SF	Cost
1	Walls	Cellulose Net & Blow	4	14	3,264	\$6,528
2	Attic Floor	Cellulose Open Blow	9	33	3,260	\$4,727
3	Attic Floor	Cellulose OB to R60 Adder	6	22	3,260	\$1,141
4	Attic	Air Sealing	0	N/A	20	\$1,400
5	Attic	Duct Capped & Sealed	0	N/A	6	\$660
6					0	\$0
	Total					\$14,456

* Assumes that ductwork will be removed to the attic floor and left clean for air sealing.
Insulation costs were provided by EnergiaUS located in Holyoke, MA.

Energía, LLC
242 Suffolk Street
Holyoke, MA 01040
(413) 322-3111

ECM#2		Summary of Energy Savings Due to Attic Insulation				
		Baseline Heat Load	After ECM #2	Savings	%	
		MMBTU	MMBTU	10E6 Btu/yr	Reduction	
	Fuel Energy Usage (MMBtu/yr)	159.43	130.20	29.23	18.3%	
	New Boiler System efficiency	92%	92%			
	Fuel Energy Usage (MMBtu/yr)	173	142			
	Energy Savings	% Reduction	Propane Use after ECM1	Gallons Saved	\$/Unit	\$ Saved
		18.3%	1,678	308	\$2.150	\$661
					Total Savings (\$)	\$661
		Measure	Cost	Savings	Payback	
			\$	\$	Years	
	Attic Insulation&		\$7,828	\$661	11.8	
	Air Sealing	\$7,828	ECM2	\$661	11.8	
	Note:					
	Cost estimates were developed by BEA based upon quotes by EnergiaUSA					

ECM#3 Summary of Energy Savings Due to Wall & Attic Insulation						
		Baseline Heat Load	After ECM #2	Savings	%	
		MMBtu	MMBtu	10E6 Btu/yr	Reduction	
Fuel Energy Usage (MMBtu/yr)		130.20	49.31	80.89	62.1%	
New Boiler System efficiency		92%	92%			
Fuel Energy Usage (MMBtu/yr)		142	54			
Energy Savings						
		% Reduction	Propane Use after ECM1 &	Gallons Saved	\$/Unit	\$ Saved
		62.1%	1,370	851	\$2.150	\$1,830
				Total Savings (\$)		\$1,830
			Cost	Savings	Payback	
		Measure	\$	\$	Years	
Wall Insulation	\$6,528	ECM3	\$6,528	\$1,830	3.6	
Note: Cost estimates were developed by BEA based upon quotes by EnergiaUSA						

ANNUAL BUILDING HEAT BALANCE

EXISTING CONDITIONS

HEAT BALANCE			
GAINS AND LOSSES		BTU/HEATING SEASON* 1E6	
CONDUCTION LOSSES		-184.7	
INFILTRATION LOSSES		-51.6	
VENTILATION LOSSES		0.0	
SOLAR GAIN		60.5	
OCCUPANT GAIN		6.6	
ELECTRICAL GAIN		9.8	
NET HEATING DEMAND		-159.4	
	Net Heating Demand (MMbtu)	/Energy Required (MMbtu)	Seasonal Efficiency %
	159.4	246	65%

CONDUCTION LOSSES							
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Basement	264	6	0	20	0	
		264	18	0	20	0	
		264	24	212	20	27	26.9
2	First Floor Main	1,008	6	140	35	30	
		1,008	18	140	25	63	
		1,008	24	72	20	35	127.9
3	First Floor Office	236	6	140	35	7	
		236	18	140	25	15	
		236	24	72	20	8	29.9
Total UA		1,507	Conduction Total			184.7	

INFILTRATION LOSSES									
0.4									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Basement	20,758	0.40	18	0	0.018	20	0.0	
		20,758	0.40	24	212	0.018	20	15.2	
	Occ.	20,758	0.40	6	0	0.018	20	0.0	15.2
2	First Floor Main	31,136	0.45	18	140	0.018	25	15.9	
		31,136	0.45	24	72	0.018	20	8.7	
	Occ.	31,136	0.48	6	140	0.018	35	7.9	32.5
3	First Floor Office	3,758	0.45	18	140	0.018	25	1.9	
		3,758	0.45	24	72	0.018	20	1.1	
	Occ.	3,758	0.48	6	140	0.018	35	1.0	3.9
Infiltration Total									51.6

HEAT LOSS COEFFICIENTS					
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)	UA-Value (BTU/hr-F)
1	Basement	Roof	0.097	0	0
		Walls	0.302	675	204
		Below grade	0.000	1,240	0
		Doors	0.625	42	26
		Windows	0.400	27	11
		Slab/Floor	0.008	2,883	23
		Wing UA Total			
2	First Floor Main	Roof	0.097	2,883	205
		Walls	0.279	2,119	591
			0.000	0	0
		Doors	0.625	36	23
		Windows	0.400	473	189
		Slab/Floor	0.040	0	0
		Wing UA Total			
3	First Floor Offices	Roof	0.097	348	34
		Walls	0.279	548	153
			0.000	0	0
		Doors	0.625	0	0
		Windows	0.400	88	35
		Slab/Floor	0.040	348	14
		Wing UA Total			
Building Total UA:					1507.4

Riverside Building				
Window Solar Heat Gain				
Window Orientation	Solar Heat Gain Factor (BTU/SF) Heating Season 40 N Latitude	Window Area	Shading Factor (Max = .52)	Total BTU per Heating Season *E6
North	37,730	220	0.49	4.1
Northeast	58,231	0	0.49	0.0
South	315,304	363	0.49	56.1
Southeast	256,605	0	0.49	0.0
East	150,216	0	0.49	0.0
Northwest	58,231	0	0.49	0.0
West	150,216	5	0.49	0.4
Southwest	256,605	0	0.49	0.0
Totals		588		60.5

Temperature & Schedule Information							
Building Name: Riverside Building							
Total Heating Days	212	Floor SF	6,114				
Outdoor Winter Temperature	35						
Wing name	Occupied Temp.	Unoccupied Temp. Night	Unoccupied Temp. Off days	Htg System Occ. Hrs per day *	Includes 1.5 warm-up period	Occ Level Heating Days	
1	Basement	55	55	55	6	not in use	0
2	First Floor Main	70	60	55	6	in use 5 days per week	140
3	First Floor Offices	70	60	55	6	in use 5 days per week	140

ANNUAL BUILDING HEAT LOADS AFTER ATTIC INSULATION & AIR SEALING

HEAT LOAD AFTER ATTIC INSULATION		
GAINS AND LOSSES	BTU/HEATING SEASON* 1E6	
CONDUCTION LOSSES	-159.5	
INFILTRATION LOSSES	-47.7	
VENTILATION LOSSES	0.0	
SOLAR GAIN	60.5	
OCCUPANT GAIN	6.6	
ELECTRICAL GAIN	9.8	
NET HEATING DEMAND	-130.2	

CONDUCTION LOSSES							
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Basement	264	6	0	20	0	
		264	18	0	20	0	
		264	24	212	20	27	26.9
2	First Floor Main	837	6	140	35	25	
		837	18	140	25	53	
		837	24	72	20	29	106.3
3	First Floor Office	208	6	140	35	6	
		208	18	140	25	13	
		208	24	72	20	7	26.3
Total UA		1,309			Conduction Total		159.5

INFILTRATION LOSSES									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Basement	20,758	0.40	18	0	0.018	20	0.0	
		20,758	0.40	24	212	0.018	20	15.2	
		Occ.	20,758	0.40	6	0	0.018	20	0.0
2	First Floor Main	31,136	0.40	18	140	0.018	25	14.1	
		31,136	0.40	24	72	0.018	20	7.7	
		Occ.	31,136	0.43	6	140	0.018	35	7.1
3	First Floor Office	3,758	0.40	18	140	0.018	25	1.7	
		3,758	0.40	24	72	0.018	20	0.9	
		Occ.	3,758	0.43	6	140	0.018	35	0.9
Infiltration Total								47.7	

HEAT LOSS COEFFICIENTS					
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)	UA-Value (BTU/hr-F)
1	Basement	Roof	0.015	0	0
		Walls	0.302	675	204
		Below grade	0.000	1,240	0
		Doors	0.625	42	26
		Windows	0.400	27	11
		Slab/Floor	0.008	2,883	23
		Wing UA Total			
2	First Floor Main	Roof	0.016	2,883	34
		Walls	0.279	2,119	591
			0.000	0	0
		Doors	0.625	36	23
		Windows	0.400	473	189
		Slab/Floor	0.040	0	0
		Wing UA Total			
3	First Floor Offices	Roof	0.016	348	6
		Walls	0.279	548	153
			0.000	0	0
		Doors	0.625	0	0
		Windows	0.400	88	35
		Slab/Floor	0.040	348	14
		Wing UA Total			
Building Total UA:				1308.6	

**ANNUAL BUILDING HEAT LOADS
AFTER WALL INSULATION &
ATTIC INSULATION &
AIR SEALING**

HEAT LOAD AFTER WALL & ATTIC INSULATION	
GAINS AND LOSSES	BTU/HEATING SEASON* 1E6
CONDUCTION LOSSES	-78.6
INFILTRATION LOSSES	-47.7
VENTILATION LOSSES	0.0
SOLAR GAIN	60.5
OCCUPANT GAIN	6.6
ELECTRICAL GAIN	9.8
NET HEATING DEMAND	-49.3

CONDUCTION LOSSES							
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Basement	111	6	0	20	0	
		111	18	0	20	0	
		111	24	212	20	11	11.3
2	First Floor Main	428	6	140	35	13	
		428	18	140	25	27	
		428	24	72	20	15	54.4
3	First Floor Office	102	6	140	35	3	
		102	18	140	25	6	
		102	24	72	20	4	12.9
Total UA		641	Conduction Total			78.6	

HEAT LOSS COEFFICIENTS					
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)	UA-Value (BTU/hr-F)
1	Basement	Roof	0.015	0	0
		Walls	0.075	675	51
		Below grade	0.000	1,240	0
		Doors	0.625	42	26
		Windows	0.400	27	11
		Slab/Floor	0.008	2,883	23
		Wing UA Total			
2	First Floor Main	Roof	0.016	2,883	34
		Walls	0.086	2,119	182
			0.000	0	0
		Doors	0.625	36	23
		Windows	0.400	473	189
		Slab/Floor	0.040	0	0
Wing UA Total				428.3	
3	First Floor Offices	Roof	0.016	348	6
		Walls	0.086	548	47
			0.000	0	0
		Doors	0.625	0	0
		Windows	0.400	88	35
		Slab/Floor	0.040	348	14
Wing UA Total				101.7	
Building Total UA:				641.1	